

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.015/KARYA-26/01

Dated: 03/05/2026

It is certified that an inspection team headed by Ashutosh Singh from Executive Engineer, Construction U P Jal Nigam, Ballia inspected Sunbeam School, Agarsanda, Ballia on 02/05/2026 and, on the basis of the Water Test Report (Attached) bearing no. 015/KARYA-26/01 dated 03/05/2026 of (PHED Lab), certified that Sunbeam School, Agarsanda, Ballia has safe drinking water facilities for the students and staff members of the institution. The school also maintains hygienic sanitation conditions in the school building and campus as per the norms prescribed by the Central/State/U.T. Government.

This certificate is valid till 02/05/2027

yele 02/05/26
Executive Engineer
Construction Division
U P Jal Nigam-Ballia
Signature with Seal:

To,
(Sunbeam School)
Agarsanda, Ballia U.P.

Note: This certificate is to be issued by an authorized officer/PHED Lab/local body.


Manager/Correspondent of
Sunbeam School, Ballia


PRINCIPAL
Sunbeam School
Ballia
UDISE CODE:09631300403
CBSE Affi. No: 2131962
School Code: 70205

Analysis Report


District Level Water Analysis Laboratory,

Uttar Pradesh Jal Nigam, (Rural), Ballia, 277001

Report No	015/KARYA-26/01	Date	03/05/2026	Page No	1/1
Customer Details					
Office Name and Address	SUNBEAM SCHOOL, AGARSANDA, BALLIA				
Ref. Letter No. & Date					
Basic details of sample					
District	BALLIA	Block	HANUMANGANJ		
Gram Panchayat		Village	AGARSANDA		
Habitation		Location			
Water Source	DRINKING WATER	Sample No.	015		
Quality of Sample	1000ml	Date of S.C.	02/05/2026		
Receiving Date	02/05/2026	S. Collector	RAMESH KUMAR		
Sample Depositor	RAMESH KUMAR				
Analysis Start Date	02/05/2026	Analysis Completion Date			

Technical Data of Analysis					
S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	7.08	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2012
3	Turbidity (NTU)	2.76	1	5	IS 3025 (Part 10): 2012
4	TDS (Mg/L)	285.4	500	2000	IS 3025 (Part 16): 2018
5	Chloride (Mg/L)	389.80	250	1000	IS 3025 (Part 32): 2014
6	Total Alkalinity (Mg/L)	234.00	200	600	IS 3025 (Part 23): 2018
7	Total Hardness (Mg/L)	280.00	200	600	IS 3025 (Part 21): 2019
8	Sulphate (Mg/L)	18.00	200	400	IS 3025 (Part 24): 2009
9	Nitrate (Mg/L)	23.00	45	45	APHA 23 Edition 2017, Meth. 4500 NO ₃ B
10	Fluoride (Mg/L)	0.03	1	1.5	IS 3025 (Part 68): 2008 (electro. Chem. Probe Meth.)
11	Iron (Mg/L)	0.1	1.0	1.0	IS 3025 (Part 53): 2003 (1.10 Phenolphthalein Method)
13	Residual Chlorine (FRC)	0.01	0.2	1	IS 3025 (Part 26): 2003
14	Calcium (as Ca)	118.00	75	200	IS 3025 (Part 40): 2019
15	Magnesium (as Mg)	56.54	30	100	IS 3025 (Part 46): 2019
16	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05): 2018
17	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 07&08): 2017
18	Conductivity (µs/cm)	500.00	NA	NA	IS 3025 (Part 14): 2002
19	E. coli (CFU)	Nil	Absent	Absent	IS 15185:2016

- Note :- 1. This certificate refers only to the particular sample (S) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue


 (ASHUTOSH SINGH)
 Lab Technician
 Report Prepared by

Y&L 02/05/26
 Executive Engineer
 Construction Division
 U.P. Jal Nigam-Ballia

Laboratory Contact details- 8417056000


 Manager/Correspondent of
 Sunbeam School, Ballia


 PRINCIPAL
 Sunbeam School
 Ballia
 UDISE CODE:09631300403
 CBSE Affi. No: 2131962
 School Code: 70205